



**INTEGRATED SANITARY MASTER PLAN**  
Municipal Class Environmental Assessment –  
Volume 2 (Technical Memorandums)

May 2, 2024

Prepared for:  
City of Kitchener

Prepared by:  
Stantec Consulting Ltd.

Project Number: 165640334

<b>Revision</b>	<b>Description</b>	<b>Author</b>	<b>Quality Check</b>
Draft	Draft MP	HB / SM	JP / DE
Final	Final MP	HB / SM	JP / DE

# Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>V</b>
<b>ACRONYMS / ABBREVIATIONS.....</b>	<b>X</b>
<b>1 INTRODUCTION .....</b>	<b>1</b>
1.1 Study Area .....	1.1
1.2 Municipal Class Environmental Assessment Process .....	1.2
1.2.1 Class EA Project Classification .....	1.5
1.2.2 Section 16 Order Process .....	1.5
1.3 Consultation .....	1.6
1.3.1 Project Contact List .....	1.6
1.3.2 Project Notices .....	1.6
1.3.3 Public Consultation .....	1.7
1.3.4 Agency Stakeholder Consultation .....	1.8
1.3.5 Indigenous Consultation .....	1.9
1.4 Report Organization.....	1.9
1.4.1 Technical Memos .....	1.10
<b>2 PROBLEM STATEMENT AND OPPORTUNITY IDENTIFICATION .....</b>	<b>2.1</b>
<b>3 PLANNING &amp; POLICY FRAMEWORK.....</b>	<b>3.1</b>
3.1 Federal Legislation.....	3.1
3.1.1 Canadian Environmental Assessment Act .....	3.1
3.1.2 Fisheries Act.....	3.1
3.1.3 Species at Risk Act.....	3.1
3.2 Provincial Policies and Legislation.....	3.2
3.2.1 The Planning Act .....	3.2
3.2.2 Provincial Policy Statement .....	3.2
3.2.3 Endangered Species Act.....	3.3
3.2.4 Climate Change .....	3.4
3.2.5 Grand River Conservation Authority.....	3.4
3.3 Municipal Planning Policies .....	3.4
3.3.1 Region of Waterloo Official Plan .....	3.4
3.3.2 Region of Waterloo Wastewater Treatment Master Plan .....	3.5
3.3.3 City of Kitchener Official Plan .....	3.5
<b>4 EXISTING CONDITIONS .....</b>	<b>4.1</b>
4.1 Natural, Social, and Economic Environment .....	4.1
4.1.1 Social Environment.....	4.1
4.1.2 Natural Environment.....	4.1
4.1.3 Economic Contributions.....	4.1
4.2 Existing Population .....	4.1
4.3 Existing Sanitary System .....	4.5
4.3.1 Background Reports.....	4.5
4.3.2 Cross-Border Agreements.....	4.5
4.3.3 Existing Infrastructure and Inventory .....	4.7
4.3.4 Monitored Flow .....	4.10



# Integrated Sanitary Master Plan

4.4	Sanitary Hydraulic Model.....	4.17
4.4.1	Existing Hydraulic Model and Platform Review.....	4.17
4.4.2	Model Updates.....	4.18
4.4.3	Flow Generation Updates.....	4.18
4.4.4	External Flow Input and Boundary Conditions.....	4.18
4.4.5	Hydraulic Model Calibration.....	4.21
4.4.6	Hydraulic Model Validation.....	4.24
<b>5</b>	<b>FUTURE SANITARY SYSTEM CONDITIONS.....</b>	<b>5.1</b>
5.1	Population and Growth Projections.....	5.1
5.2	Hydraulic Model Updates.....	5.3
5.2.1	Future Population.....	5.3
5.2.2	Infrastructure Updates.....	5.3
5.2.3	Pumping Stations.....	5.3
<b>6</b>	<b>DESIGN CRITERIA &amp; LEVEL OF SERVICE.....</b>	<b>6.1</b>
6.1	Sanitary Collection System Criteria.....	6.1
6.1.1	Design Sewage Flows.....	6.1
6.1.2	Sewer Design.....	6.4
6.1.3	Design of Pump Stations.....	6.5
6.2	Sanitary Collection System Level of Service.....	6.6
6.2.1	Sanitary Sewers.....	6.7
6.2.2	Pump Stations.....	6.9
6.2.3	Sensitivity Testing.....	6.9
<b>7</b>	<b>ASSESSMENT OF EXISTING AND FUTURE SANITARY INFRASTRUCTURE.....</b>	<b>7.10</b>
7.1	Design Criteria.....	7.10
7.2	Climate Change.....	7.11
7.3	Critical Failure Analysis.....	7.11
7.4	Modelling & Analysis.....	7.12
7.4.1	Assessment Approach.....	7.12
7.4.2	Assessment Results.....	7.12
7.5	Condition-Based System Assessment.....	7.38
7.5.1	Assessment Approach.....	7.38
7.5.2	Assessment Results.....	7.39
<b>8</b>	<b>DEVELOPMENT &amp; EVALUATION OF SERVICING STRATEGY ALTERNATIVES..</b>	<b>8.1</b>
8.1	Evaluation Criteria.....	8.1
8.2	Alternative Servicing Solutions.....	8.2
8.2.1	Alternative 1 – Do Nothing.....	8.2
8.2.2	Alternative 2 – Shaping Community Growth.....	8.2
8.2.3	Alternative 3 – Infrastructure Updates.....	8.3
8.2.4	Alternative 4 – Data Acquisition, Flow Monitoring and Inflow and Infiltration Mitigation Programs.....	8.3
8.3	Alternative Infrastructure Update Solutions.....	8.4
8.4	Recommended Servicing Solutions.....	8.33
8.5	Municipal Class Environmental Assessment Project Schedule Classification.....	8.33
<b>9</b>	<b>PROJECT IMPLEMENTATION.....</b>	<b>9.1</b>
9.1	Capital Projects.....	9.1
<b>10</b>	<b>INNOVATION.....</b>	<b>10.1</b>



# Integrated Sanitary Master Plan

10.1	What is a Smart City and Smart Utility?.....	10.1
10.2	Foundation of a Smart Utility: Digital Transformation.....	10.1
10.3	The Smart Utility as the Digital Utility of the Future.....	10.3
10.4	Energy Optimization and Renewable Energy.....	10.4
10.5	Recommendations.....	10.5
<b>11</b>	<b>CLOSING.....</b>	<b>11.1</b>

## LIST OF TABLES

Table ES-1-1: Summary of Budgetary Estimates.....	ix
Table 4-1: Existing Population.....	4.1
Table 4-2: City of Kitchener Cross-Border Agreements.....	4.6
Table 4-3: Sanitary Pump Station Information.....	4.9
Table 4-4: Flow Meter & Metershed Characteristics.....	4.13
Table 4-5: Available 2021 Rain Gauge Network.....	4.15
Table 4-6: Storm Event Characteristics.....	4.16
Table 4-7: Existing Model Boundary Conditions.....	4.19
Table 4-8: Dry Weather Flow Parameters.....	4.21
Table 5-1: Population Projections.....	5.1
Table 5-2: Updated Pumping Station Firm & Rated Capacities Based on Theoretical Operation.....	5.4
Table 6-1: Domestic Sewage Generation Rates.....	6.2
Table 6-2: ICI Sewage Generation Rates.....	6.3
Table 6-3: Extraneous Flow Generation Rates.....	6.3
Table 6-4: Comparison of Sanitary Pipe Design Criteria.....	6.4
Table 6-5: Comparison of Sanitary MH Design Criteria.....	6.4
Table 6-6: Pump Station Criteria.....	6.6
Table 7-1: Selected Critical Trunk Sewers for Failure Analysis.....	7.11
Table 7-2: Existing Conditions Sanitary Sewer Problem Areas.....	7.14
Table 7-3: Existing Conditions Pumping Station Performance.....	7.15
Table 7-4: 2031 Future Conditions Sanitary Sewer Problem Areas.....	7.22
Table 7-5: 2031 Future Conditions Pumping Station Performance.....	7.23
Table 7-6: 2051 Future Conditions Sanitary Sewer Problem Areas.....	7.30
Table 7-7: 2051 Future Conditions Pumping Station Performance.....	7.31
Table 7-8: Gravity Sewers Currently in Poor Condition.....	7.39
Table 8-1: Evaluation Criteria.....	8.1
Table 8-2: Sewer Design Criteria.....	8.5
Table 8-3: Existing and Future Conditions Capacity-Based Sewer Solutions.....	8.7
Table 8-4: Alternatives Evaluation.....	8.11
Table 8-5: Climate Change Impacts to Proposed Solutions.....	8.13
Table 8-6: Sewer Asset Renewal Projects (Near-Term).....	8.17
Table 8-7: Sanitary Pumping Station Asset Renewal Projects.....	8.31
Table 8-8: Sanitary Pumping Station Scada System Upgrades.....	8.31
Table 8-9: MCEA Project Schedule Classifications.....	8.33
Table 9-1: Short Term Projects (2024 - 2027) Prioritization & Annual Costing.....	9.2
Table 9-2: Medium Term Projects (2028 – 2031) Prioritization & Annual Costing.....	9.6
Table 9-3: Data Acquisition & Management Programs Annual Costing.....	9.6
Table 9-4: Summary of Annual Costing for 2024 - 2031.....	9.7
Table 9-5: Long-Term Projects (2032 - 2051).....	9.1



**LIST OF FIGURES**

Figure 1-1: Study Area ..... 1  
Figure 1-2: Municipal Class Environmental Assessment Process..... 3  
Figure 4-1: Social Environment..... 4.2  
Figure 4-2: Natural Environment..... 4.3  
Figure 4-3: Economic contributions ..... 4.4  
Figure 4-4: Sanitary Sewer System ..... 4.8  
Figure 4-5: Trunk Sewer Network and Sewershed Classification..... 4.11  
Figure 4-6: 2021 Flow Monitoring Program Meter & Rain Gauge Locations ..... 4.12  
Figure 4-7: 2021 Flow Meter Schematic ..... 4.15  
Figure 4-8: Boundary Conditions Locations..... 4.20  
Figure 4-9: Hydraulic Model Wet Weather Validation at the WWTP ..... 4.24  
Figure 5-1: Growth Projections ..... 5.2  
Figure 7-1: Existing Conditions Sanitary Sewer System Dry Weather Flow HGL & Surcharge Results. 7.17  
Figure 7-2: Existing Conditions Sanitary Sewer System 5-Year HGL & Surcharge Results ..... 7.18  
Figure 7-3: Existing Conditions Sanitary Sewer System 10-Year HGL & Surcharge Results ..... 7.19  
Figure 7-4: Existing Conditions Sanitary Sewer System 25-Year HGL & Surcharge Results ..... 7.20  
Figure 7-5: 2031 Future Conditions Sanitary Sewer System Dry Weather Flow HGL & Surcharge Results ..... 7.25  
Figure 7-6: 2031 Future Conditions Sanitary Sewer System 5-Year HGL & Surcharge Results ..... 7.26  
Figure 7-7: 2031 Future Conditions Sanitary Sewer System 10-Year HGL & Surcharge Results ..... 7.27  
Figure 7-8: 2031 Future Conditions Sanitary Sewer System 25-Year HGL & Surcharge Results ..... 7.28  
Figure 7-9: 2051 Future Conditions Sanitary Sewer System Dry Weather Flow HGL & Surcharge Results ..... 7.34  
Figure 7-10: 2051 Future Conditions Sanitary Sewer System 5-Year HGL & Surcharge Results ..... 7.35  
Figure 7-11: 2051 Future Conditions Sanitary Sewer System 10-Year HGL & Surcharge Results ..... 7.36  
Figure 7-12: 2051 Future Conditions Sanitary Sewer System 25-Year HGL & Surcharge Results ..... 7.37  
Figure 7-13: Gravity Sewers Currently in Poor Condition ..... 7.43  
Figure 8-1: Proposed Capacity-Based Solutions ..... 8.9  
Figure 8-2: 2051 Future Conditions Sanitary Sewer System 25-Year HGL & Surcharge Results with Proposed Capacity-Based Solutions ..... 8.10  
Figure 8-3: Capacity-Based Solutions Sensitivity – 25-Year Climate Change HGL & Surcharge Results ..... 8.15  
Figure 10-1: Utility of the Future Components and Desired Outcomes ..... 10.2  
Figure 10-2: Digital UOTF Integration with Enterprise Data Management and Analytics Platform ..... 10.4

**LIST OF APPENDICES**

**APPENDIX A CONSULTATION.....1**

**VOLUME 2 TECHNICAL MEMORANDUMS**

**Technical Memo 1** – Background Review

**Technical Memo 2** – Hydraulic Analysis

- Technical Memo 2a: Model Assessment and Software Recommendation
- Technical Memo 2b: Model Plan
- Technical Memo 2c: Calibration
- Technical Memo 2d: Modelling Scenarios

**Technical Memo 3 (including TM4)** – Sanitary Servicing Analysis & Capital Infrastructure Funding and Risk Analysis and Implementation Plan

**Technical Memo 5** – Design Criteria & Level of Service



**City of Kitchener Integrated  
Sanitary Master Plan –  
Technical Memo #5: Design  
Criteria & Level of Service**

TM 5

Final



Prepared for:  
City of Kitchener


Prepared by:  
Stantec Consulting Ltd.

November 15, 2023

<b>Revision</b>	<b>Description</b>	<b>Author</b>	<b>Quality Check</b>	<b>Independent Review</b>
0	Draft	DE	FB	JP
1	Final	DE	FB	JP
2	Final v2	DE	FB	JP

## Sign-off Sheet

This document entitled City of Kitchener Integrated Sanitary Master Plan – Technical Memo #5: Design Criteria & Level of Service was prepared by Stantec Consulting Ltd. (“Stantec”) for the account of City of Kitchener (the “Client”). Any reliance on this document by any third party is strictly prohibited. The material in it reflects Stantec’s professional judgment in light of the scope, schedule and other limitations stated in the document and in the contract between Stantec and the Client. The opinions in the document are based on conditions and information existing at the time the document was published and do not take into account any subsequent changes. In preparing the document, Stantec did not verify information supplied to it by others. Any use which a third party makes of this document is the responsibility of such third party. Such third party agrees that Stantec shall not be responsible for costs or damages of any kind, if any, suffered by it or any other third party as a result of decisions made or actions taken based on this document.

Prepared by  \_\_\_\_\_  
(signature)

**Dave Eadie, P.Eng.**

Reviewed by  \_\_\_\_\_  
(signature)

**Faiz Bhatia, P.Eng., MBA**

Approved by  \_\_\_\_\_  
(signature)

**Jeff Paul, P.Eng.**

## Table of Contents

<b>1.0</b>	<b>Introduction.....</b>	<b>1.1</b>
1.1	Overview of TM#5 .....	1.1
<b>2.0</b>	<b>Sanitary Collection System Criteria.....</b>	<b>2.1</b>
2.1	Design Sewage Flows.....	2.2
2.1.1	Local vs. Trunk System .....	2.2
2.1.2	Drainage Area .....	2.2
2.1.3	Domestic Sewage Flows .....	2.2
2.1.4	ICI Sewage Flows.....	2.4
2.1.5	Extraneous Flow.....	2.4
2.2	Design of Sewers .....	2.5
2.2.1	Pipe Criteria.....	2.5
2.2.2	Maintenance Hole Criteria .....	2.6
2.3	Design of Pump Stations .....	2.7
<b>3.0</b>	<b>Sanitary Collection System Level of Service .....</b>	<b>3.1</b>
3.1	Sanitary Sewers .....	3.2
3.1.1	Difference Between Design and Existing System Performance .....	3.2
3.1.2	LOS Capacity-Based Metrics .....	3.3
3.1.3	Dry Weather Flow Performance .....	3.4
3.1.4	Wet Weather Flow Performance .....	3.4
3.2	Pump Stations .....	3.5
3.3	Sensitivity Testing.....	3.7
<b>4.0</b>	<b>Recommendations .....</b>	<b>4.1</b>

## List of Tables

Table 2-1:	Sanitary Collection System Criteria Documents .....	2.1
Table 2-2:	Domestic Sewage Generation Rates.....	2.3
Table 2-3:	ICI Sewage Generation Rates.....	2.4
Table 2-4:	Extraneous Flow Generation Rates.....	2.4
Table 2-5:	Comparison of Sanitary Pipe Design Criteria .....	2.5
Table 2-6:	Comparison of Sanitary MH Design Criteria .....	2.6
Table 2-7:	Pump Station Criteria .....	2.7
Table 3-1:	Historic Average Statistics (RMOW, 2018).....	3.6

## Appendix

Appendix A Supplementary Materials





# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Introduction  
November 15, 2023

## 1.0 Introduction

The City of Kitchener (City) is completing an Integrated Sanitary Master Plan (ISAN-MP). The purpose of the ISAN-MP is to develop an overall master plan to guide the future needs of the City for growth development and infrastructure renewal to account for updated population and employment growth projections to the 2051 planning horizon, building on the work/studies previously completed and integrating available information from ongoing studies/programs. Following the Municipal Class Environmental Assessment (EA) Process, priority and strategic projects will be evaluated to continue to efficiently and effectively operate the system, implement best management practices (including growth tracking and digital innovation), and sustainable staging and funding of wastewater capital projects.

The following tasks are being carried out for the completion of the ISAN-MP, including a series of Technical Memoranda (TM) that will comprise the content of the final Master Plan document (note that Task 3, 4 and 6 have been consolidated into a single TM#3):

- Task 1: Background Data Review (TM#1)
- Task 2: Hydraulic Analysis (TM#2)
- Task 3: Sanitary Servicing Analysis (TM#3)
- Task 4: Capital Infrastructure Funding and Risk Analysis (TM#3)
- Task 5: Design Criteria, Level of Service & Sensitivity Analysis (TM#5)**
- Task 6: Growth Management and Implementation Plan (TM#3)
- Task 7: Communications and Community Engagement
- Task 8: Sanitary Servicing Master Plan / Innovation Strategy

### 1.1 Overview of TM#5

The work of the preceding Technical Memoranda #1 and #2 provide the background and basis for hydraulic assessment in the ISAN-MP, establishing the updated hydraulic model for use in evaluation of system capacity over existing and future growth scenarios in Task 3. Task 5 involves a review of the current design criteria documents / sources of information used to guide the sizing of new / replaced sanitary infrastructure, and for the assessment of system performance relative to a preferred service level provided to municipal customers with consideration to sensitivity analysis for resiliency to impacts of climate change.

This document summarizes the available data sources and current sanitary sewer / pump station design criteria, and level-of-service (LOS) considerations typically applied in the City and Ontario municipalities. The information is contrasted against the Ministry of Environment (MECP) criteria, with recommendations for improvements where required. In this document, there is a distinction between design criteria as applied to new developments and the sizing of new pipes (i.e., typical design sheet methodology), versus system-wide LOS performance and Master Planning triggers for infrastructure upgrades as assessed with the City's dynamic hydraulic model. Section 2 speaks to standard design sheet methodologies in support



# **CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE**

Introduction

November 15, 2023

of development applications and pipe sizing and pump station capacity, while Section 3 speaks to the metrics used in this Master Plan for pipe and pump station assessment and triggers for upgrades.



# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Criteria  
November 15, 2023

## 2.0 Sanitary Collection System Criteria

The following subsections outline the specific criteria reviewed pertaining to sanitary sewer and pump station design. The referenced sources are listed in **Table 2-1**, complete with reference ID that is used throughout this document.

**Table 2-1: Sanitary Collection System Criteria Documents**

Ref. ID	Title	Author	Year
KDM	Kitchener Development Manual	City of Kitchener	2021
DGSSMS	Region of Waterloo and Area Municipalities Design Guidelines and Supplemental Specifications for Municipal Services	BMP Technical Sub-Committee, Region of Waterloo	2023
KSS	Kitchener Standard Specifications	City of Kitchener	2020
KPF	Kitchener Design Standards and Procedures Manual: Wastewater Pumping Facilities	City of Kitchener	2022
MECP (2008)	Design Guidelines for Sewage Works (for Pump Stations only)	MECP	2008
MECP (2023)	Design Criteria for Sanitary Sewers, Storm Sewers and Forcemains for Alterations Authorized under an Environmental Compliance Approval	MECP	2023

It is noted that the KDM refers to the DGSSMS for all criteria and only indicates specific values where the City deviates from the DGSSMS. Since 2021, the MECP has adopted a Consolidated Linear Infrastructure Permissions Approach (CLI) for low-risk projects related to sanitary collection and stormwater management, which replaces the previous “pipe by pipe” Certificate of Authorization (CoA) approach. Effectively, the CLI is a pre-authorization that allows municipalities to proceed with certain collection system alterations without first obtaining individual Ministry permission, as long as the work is carried out in accordance with the requirements of the municipality’s CLI Environmental Compliance Approval (ECA), including meeting MECP design criteria (Version 2.0, dated May 31, 2023), found at the following City of Kitchener link:

([https://www.kitchener.ca/en/resourcesGeneral/Documents/INS\\_SSU\\_Design\\_Criteria.pdf](https://www.kitchener.ca/en/resourcesGeneral/Documents/INS_SSU_Design_Criteria.pdf)).

The City of Kitchener ECA number is 019-W601, granted January 29, 2023, which is found at the following link: [https://www.kitchener.ca/en/resourcesGeneral/Documents/INS\\_SSU\\_ECA\\_019-W601.pdf](https://www.kitchener.ca/en/resourcesGeneral/Documents/INS_SSU_ECA_019-W601.pdf)



# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Criteria  
November 15, 2023

## 2.1 Design Sewage Flows

### 2.1.1 Local vs. Trunk System

The City of Kitchener designates trunk sewers as pipes with 375 mm diameter and larger. Therefore, local sewers are less than 375 mm diameter. The City's GIS Asset data provides an indication of the sub-drainage area related to the defined trunk sewersheds (e.g., Upper Schneider – Sandrock), which helps to communicate tributary connectivity and location within the trunk sewershed.

### 2.1.2 Drainage Area

There is limited reference to the basis of establishing drainage areas in the background documents. As noted in TM2, the definition of the drainage area is a critical component for both the establishment of consistent assessment for sanitary flow generation and infiltration and inflow unit rates. Typically, drainage areas are assessed for new or re-development based on the parcel fabric with extension across road right-of-ways, based generally on a maintenance hole-to-maintenance hole delineation. With the modifications to the system-wide hydraulic model set-up, which is based on Parcel-Based subcatchments for development and a Buffer-Based subcatchment for rainfall-derived infiltration and inflow (RDII), there is opportunity to promote consistency in the application of area extents for both private and system-wide assessments. At the development application level, use of the Parcel-Based subcatchments is recommended for both population and RDII design sheet calculations. Depending on the type of development (greenfield vs. infill), there may be cases where an area less than the parcel size is more appropriate for generating reasonable RDII (e.g., around trunk sewers with no service connections), and the Buffer-based area approach of using 45 m surrounding gravity pipes should be used.

### 2.1.3 Domestic Sewage Flows

**Table 2-2** presents a comparison of the domestic (residential) sewage generation rate criteria within the reference documents, with section numbers indicated.







# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Criteria  
November 15, 2023

monitoring data, the importance of the impact of the allowance on the overall system is reduced since extraneous flow is captured more directly and associated with varying rainfall. For design purposes, and if using the overall parcel as the basis for the area calculation, the use of 0.15 L/s/ha is recommended to remain. See discussion on drainage areas in Section 2.1.2.

## 2.2 Design of Sewers

In general, the design of sewers is captured by the MECP Guidelines that provide the overarching minimum standard that is superseded by the Regional and Municipal guidelines. The Mannings equation is uniformly recommended for use in Ontario for the sizing of sewers and assessment of pipe capacity.

### 2.2.1 Pipe Criteria

**Table 2-5** compares the sanitary pipe design criteria from the reference documents. In general, the sewer design criteria are similar to the MECP Guidelines. The flow velocities comply with the MECP Guidelines, with additional considerations for subcritical flow.

**Table 2-5: Comparison of Sanitary Pipe Design Criteria**

Criterion	MECP (2023)	DGSSMS	KDM
Min. Pipe Size	2.3: 200 mm (150 mm is acceptable if it is demonstrated in the design that there is no risk of clogging, and the design is accepted by the Owner)	B.3.1.4: Per MECP	Defer to DGSSMS
Min. Pipe Slope	-	B.3.1.6: 1 <sup>st</sup> Reach: 1.0% All Other Pipes: 0.5%	E.1.3: 1 <sup>st</sup> Reach: per DGSSMS All Other: As a function of flow velocity
Velocities	2.4: Min: 0.6 m/s when flowing full Max: 3.0 m/s	B.3.1.7: Per MECP	E.1.4: Min: 0.8 m/s when flowing full Max: 3.0 m/s
Pipe Depth	2.8: Installed at sufficient depth to prevent freezing, considering traffic load and manufacturer recommendations	B.3.1.10: Min. 2.8 m to Obvert > 5.0 m may require secondary shallow sewer	E.1.5: Per DGSSMS
Capacity Ratio	-	-	E.1.2: Local: <95% Pipe Full Capacity Trunk: <85% Pipe Full Capacity
Roughness	2.2: 0.013	B.3.1.5: 0.013	Defer to DGSSMS



# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Criteria  
November 15, 2023

Considerations:

- Add that the pipe should be ideally designed to convey the peak design flow at no greater than 80% d/D, to allow for air movement in the open channel.
- Adding clarity that velocities should also be checked against Actual Flow velocity in addition to theoretical Pipe Full, to flag potential operational issues when pipes do not frequently flow full.
- Adding a section related to Construction Dewatering requirements, and assessment of impact on downstream collection system.
- Systemwide Level of Service is discussed further in Section 3

## 2.2.2 Maintenance Hole Criteria

Table 2-6 presents a comparison of the maintenance hole (MH) criteria.

**Table 2-6: Comparison of Sanitary MH Design Criteria**

Criterion	MECP (2023)	DGSSMS	KDM
Minimum Invert Drops	2.10.4: Based on bend angle: 0°: 0.025 m 45° Turn: 0.03 m 90° Turn: 0.05 m Sewer grade may be maintained across maintenance holes provided minimum required flow velocity is maintained	B.3.2.6: 0° – 45°: 0.030 m 45° – 90°: 0.060 m	Defer to DGSSMS
Change in Flow Direction	-	B.3.2.9: Must be less than 90° Pipes 675mm or greater must be less than 45°	Defer to DGSSMS
Benching	-	D.3.3.4: All sanitary MHs benched to springline Slope: 8%	Defer to DGSSMS
Drop Structures	2.10.6: Drop should be provided for sewer entering ≥610mm above MH invert External drop connection preferred; internal drops if necessary to be secured to interior wall of MH for access and cleaning Where drop not feasible, alternative methods of energy dissipation and minimizing air entrainment and odour problems to be specified	B.3.2.4: Defers to MECP Only external drops allowed	Only external drops allowed
Change in Pipe Size	2.10.5: When smaller sewer joins larger one, invert of larger sewer should be lowered sufficiently to maintain the same energy gradient, or pipe obverts are matched	-	-











# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Level of Service

November 15, 2023

*effective levels of service lead to reactive management and potentially to high social, environmental and financial costs. The emphasis is to define, develop and implement a level of service framework that results in a consistent set of expectations across infrastructure categories that support the city's sustainability and resiliency targets.*

The City's Sanitary Asset Management Plan (Phase 2) Final report (2018) describes that LOS falls into a number of categories; qualitative customer expectations, legislated obligations, and technical standards. LOS in the context of this document refers to Technical Standards. As of 2017, the Core Service Key Result Indicators (KRI) are provided on an annual basis from the Sanitary Utility, which include:

1. % of length of sanitary sewer pipes flushed
2. # of kilometers of sanitary sewer pipe replaced/rehabilitated
3. % sanitary sewer pipes inspected
4. # of sanitary main blockages per 100 km of pipe
5. # of spills that reach the environment/total # of spills

These are operational metrics to provide long-term measuring of system performance over time. A legislated obligation is based on Provincial guidelines regarding protection of the environment:

- "Maintain a Sanitary Utility which takes the utmost care in protecting the local environment, meeting all regulatory requirements"
- Reference is to the MECP guidance
- Kitchener retains a copy of the MECP form Grand River Watershed Sewage Discharge Notification Form for Spills and Bypasses

Sanitary network modelling is identified as an important metric for assessing the LOS via project model results compared to the design criteria. The following section further discusses sanitary system LOS and performance metrics.

## 3.1 Sanitary Sewers

A LOS analysis provides perspective into the resiliency of the collection system and assists in identifying if modifications to the existing infrastructure are required. A LOS analysis begins with understanding the performance of the collection system under dry weather flow conditions. The extent of the existing system's ability to accommodate increasingly infrequent wet weather flow events is then explored.

### 3.1.1 Difference Between Design and Existing System Performance

Municipalities who maintain and operate a hydraulic model face a challenge of assessing development applications completed through standard Design Sheets using the flow generation criteria outline in this document, which are fundamentally different than the methods of flow generation applied in the hydraulic model. The hydraulic model is based on macro-level population distributions with flow generation rates calibrated to trunk-level flow monitoring data. The input parameters in the hydraulic model are different than that used in design of new sewers, which makes it difficult to integrate the two data sources and can





# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Level of Service

November 15, 2023

- SS = 2: surcharged, with the slope of the HGL greater than the pipe indicating insufficient capacity in the pipe

From a risk to flooding perspective, the depth of the HGL relative to the surface is commonly referred to as the HGL Freeboard. Within the hydraulic model, the maximum water surface elevation per node can be subtracted from the ground elevation of the node to compute the HGL Freeboard, where:

- HGL Freeboard > Threshold: water level is below the threshold and there is no risk of flooding
- HGL Freeboard < Threshold: water level is within the threshold and is a risk to basement flooding
- HGL Freeboard < 0: water level has breached the surface and is spilling to the environment

The HGL Freeboard Threshold varies from municipality to municipality, but is typically associated with an assumed depth to basement or underside of footing in the 1.8 m to 2.1 m range. Use of the HGL Freeboard and SS can provide valuable insights into system-wide performance when thematically mapped. Coupling these metrics with design storm simulations in the calibrated hydraulic model then allows for quantification of LOS based on design storm return frequency (e.g., 25-yr storm) using the City's Intensity-Duration-Frequency data.

Another metric for the sanitary sewer system is peak velocity in m/s, used as an indicator of adequacy for conveying solids and the potential for deposition which can lead to blockages and odour concerns. Conversely, extremely high velocities can be a threat to increased headlosses or long-term pipe shifting.

Through the ISAN-MP, the LOS Capacity Metrics were defined and applied as described in the following sections.

## 3.1.3 Dry Weather Flow Performance

The performance of the collection system under dry weather flow (DWF) condition should consider the range of flows expected throughout an average day. This can be accomplished considering a diurnal pattern which can be based on appropriate sewer flow monitoring data from a dry period.

Under DWF conditions, a common rule of thumb for hydraulic performance is that the pipe should flow no greater than 80% d/D, to allow for air movement in the open channel. Peak dry weather flow velocity should be adequate to provide the sufficient scour velocity of  $\geq 0.6$  m/s, to maintain system operation.

## 3.1.4 Wet Weather Flow Performance

The collection systems' performance under wet weather flow (WWF) conditions provides insight into the relative LOS related to basement and surface flooding risk. WWF analysis can be completed using various synthetic design storm distributions over a range of return periods (i.e. frequency of events), to establish the design event to base system upgrades. In lieu of design storms, some jurisdictions apply a historic event that has caused known issues in the past and use this as their design event for WWF LOS analysis. As an example, the City of Toronto uses the May 12, 2000 design storm as measured at a specific rainfall gauge in the City to assess its sanitary system performance and designs.



# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Level of Service  
November 15, 2023

There is no Provincial design guidance for LOS. The City of Kitchener has informally adopted the 25-yr, 12-hr AES Distribution design storm for assessment of its sanitary collection system using the hydraulic model. Given the size of the Kitchener sanitary collection system, it is recommended that the AES storm distribution continue to be used as it is more reasonable than the application of the overly conservative, uniformly applied peaky design storm hyetograph of the Chicago Distribution, which is more appropriate for storm drainage systems. Note, the stormwater Master Plan indicates a 5-yr LOS for the minor storm system, and considers shorter duration (4 to 6-hr) Chicago Distribution hyetographs, which is appropriate for the scale of storm sewersheds in the urban environment. For the sanitary system, the larger trunk network and indirect nature of rainwater migration into the sewers justifies the use of the 12-hr duration, which is better suited to evaluation of both peak and volume impact of wet weather on system performance.

For the sanitary collection system LOS analysis, the work completed in Task 3 and Task 4 informed the recommendation for upsizing triggers regarding hydraulic performance. The Hydraulic Grade Line (HGL) elevations at model nodes are used as the main indicator of issues within the collection system. Elevated HGLs occur when a capacity constraint drives the upstream water levels to rise. Risk of basement flooding in the 25-yr AES, 12-hr design event is considered if the HGLs are within 1.8 m from the surface elevation, which coincides with the assumed basement elevation for homes with direct or indirect basement connections to the sewer, given the relatively low history of flooding due to sanitary back-up. Adopting this HGL freeboard from the maintenance hole surface elevation is consistent with other Ontario municipalities as a surrogate for private property flood risk.

Sewer performance is reviewed in conjunction with the elevated HGLs to determine the cause of the HGL issues observed and determine possible solutions. Sewer performance alone is generally not used to define the need to provide upgrades; however, surcharging observed in smaller events like the 5-yr AES, 12-hr storm may warrant upgrades. As noted, within the hydraulic model the Surge State (SS) is an indicator of performance. When the SS is less than 1, the pipe is considered free-flowing. When the SS is 1 or 2, the pipe is considered under backwater (slope of the HGL is less than the slope of the pipe), or bottlenecked/undersized (slope of the HGL is greater than that of the pipe), respectively.

For shallow sewers that are within 1.8 m from the surface, the HGL freeboard cannot be met; however, it is proposed that should the water level remain within the pipe and the pipe is under free-flowing conditions, that it not trigger the need for upgrades.

## 3.2 Pump Stations

LOS for pump stations is expressed as a Design Period, which is not directly related to a rainstorm return frequency. The minimum wet weather event is alluded to in the MECP guideline definitions of firm capacity, under Section 7.2.3 Pumps, where for a two-pump station, each pump should be of the same size, provide a Firm Capacity with one unit out of service, and be at least capable of handling the peak hourly flow of the 10-year Design Period. The KPF in Section 2.1 Station Capacity states “wastewater pumping facilities should be able to pump the expected 10-yr peak wastewater flows with the largest capacity pump out of operation.” From the Condition Assessment reporting completed by Kitchener, the



# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Level of Service  
November 15, 2023

highest 1-hr flow in a 10-year timeframe or within a given dataset, is referenced as the peak wet weather flow. Furthermore, Section 2.1.1 of the KPF elaborates on the Design Period for the station, with a minimum design period for ultimate conditions of 50 years and initial installation provided for a minimum 10-year design period.

The MECP does not speak specifically to wet weather response as a LOS item, or what constitutes an emergency overflow, while Section 2.1 of the KPF indicates that the peak hourly flow is the peak wet weather hourly flow. Section 2.2.3 of KPF states the emergency overflow response time is 1-hr, but does not indicate how this relates back to a design storm threshold. Once the station is in operation, actual peak wet weather flow can be derived from averaged SCADA measurements (preferably of influent flow), which can be used to derive a baseline for comparison over time. This was completed in the Region of Waterloo’s Wastewater Treatment Master Plan Update (2018), Technical Memorandum No. 1B: Sewage Pumping Station Population and Flow Projections, including the Bridgeport and Spring Valley stations in Kitchener. **Table 3-1** presents the measured and calculated metrics for the Region-owned stations in Kitchener.

**Table 3-1: Historic Average Statistics (RMOW, 2018)**

Pump Station	Firm Capacity (L/s)	Ex. Average Day Flow (L/s)	Ex. Peak Wet Weather Flow (L/s)	Wet Weather Event
Bridgeport	136	32	85	March 31, 2015
Spring Valley	245	46	207	July 14, 2015
Source: Table 1, Appendix B, Wastewater Treatment Master Plan Update, TM#1B: Sewage Pumping Station Population and Flow Projections (CIMA, 2018)				

Therefore, the LOS for pump stations is tied to Firm Capacity over the Design Period relative to the peak hourly design flow. It is recommended that influent flow to pump stations be incorporated into the SCADA system upgrades to provide both inflow and pumped discharge to enable long-term trending analytics to assess changing RDII as well as pumping equipment performance. When analyzing pump station performance LOS, energy efficiency should be considered.

For the purposes of assessing LOS in this ISAN-MP, the 10-yr AES, 12-hr storm event is recommended, where all sewage pumping facilities should be designed to pump the 10-yr peak flow with the largest pump offline (firm capacity). Pumping stations receiving 10-yr peak flows greater than the station’s firm capacity are considered to have capacity constraints. The 10-yr modelled peak flow is also compared to the firm capacity from the Environmental Compliance Approval (ECA) to determine if the current ECA is adequate for existing and future condition flows or requires amendment. Additionally, pumping station performance is evaluated with respect to overflows, in that overflows should not occur in events smaller than the 25-yr AES storm. Refer to TM#3 for more information.





# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Sanitary Collection System Level of Service  
November 15, 2023

## 3.3 Sensitivity Testing

To test the resiliency of system performance under the uncertainty of climate change (CC) impacts, it is recommended that additional model simulations be performed to inform the sensitivity of the existing and future system LOS, and potential consideration for oversizing planned capital upgrades. Application of the *IDF\_CC Web-based Tool for Updating Intensity-Duration-Frequency Curves to Changing Climate – ver. 6.5*, Western University Faculty for Intelligent Decision Support and Institute for Catastrophic Loss Reduction (open access <https://www.idf-cc-uwo.ca>) was considered as a means of defining factors to increase the 25-yr AES, 12-hr design storm rainfall intensities. Given the uncertainty in application of parameters and in the interest in defining an easily repeatable process for testing sensitivity, it was agreed with the City to apply a 20% increase to the design storm time series, herein called the 25-yr + CC event.

It is recommended that this 25-yr + CC event be applied to LOS and proposed capital project sizing to inform the sensitivity of the capacity constraint in terms of sizing and prioritization. This test should then be factored into the capital planning decision-making, and consideration for expanding the recommended solution and/or advancing the prioritization.

Additionally, the City's condition-based system assessment as part of the Asset Management program should be used in the identification and prioritization of LOS and capital upgrade triggers, considering the available metrics including condition-based scores from CCTV and the Total Wastewater Priority Assessment Score (TWPAS) accounting for criticality and risk. The City continues to collect and assess this data.





# CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE

Recommendations

November 15, 2023

- Given the relatively low history of flooding due to sanitary back-up, it is recommended that a minimum HGL freeboard of 1.8m from the maintenance hole surface elevation be applied to assess LOS under the 25-yr storm, which is consistent with other Ontario municipalities as a surrogate for private property flood risk.
- For sanitary pump stations, the 10-yr AES, 12-hr storm event is recommended for assessing LOS performance within the hydraulic model, compared against the firm capacity (i.e., largest pump offline). Additionally, pumping station overflow performance is recommended to be assessed with the 25-yr AES storm, where there shall be no overflow.
- It is recommended that this 25-yr + Climate Change modified event (20% increase to 25-yr hyetograph intensities) be applied to LOS and proposed capital projects to inform the sensitivity of the capacity constraint in terms of sizing and prioritization. This test should then be factored into the capital planning decision-making, and consideration for expanding the recommended solution and/or advancing the prioritization.
- City's condition-based system assessment as part of the Asset Management program should be used in the identification and prioritization of LOS and capital upgrade triggers, considering the available metrics including condition-based scores from CCTV and the Total Wastewater Priority Assessment Score (TWPAS) accounting for criticality and risk.



**CITY OF KITCHENER INTEGRATED SANITARY MASTER PLAN – TECHNICAL  
MEMO #5: DESIGN CRITERIA & LEVEL OF SERVICE**

**Appendix A Supplementary Materials**

**Table 4: RESIDENTIAL ZONING CRITERIA**

<u>Zoning Category</u>	<u>People/hectare</u>
R1	Not Serviceable
R2	36
R3	72
R4	143
R5	143
R6	196
R7	312
R8	387
R9	775

Source: [https://www.kitchener.ca/en/resourcesGeneral/Documents/DSD\\_ENG\\_Development\\_Manual\\_2021.pdf](https://www.kitchener.ca/en/resourcesGeneral/Documents/DSD_ENG_Development_Manual_2021.pdf)

**Table 1 - Common Sewage Flowrates for Commercial and Institutional Uses**

Description	Unit Sewage Flow (L/d)	Flow Unit Per
Shopping Centre (floor area in m <sup>2</sup> )	2.5 – 5.0	Total floor area in m <sup>2</sup>
Hospitals	900 – 1,800	Bed
Schools	70 - 140	Student
Travel Trailer Parks	340	Space (without water hook-ups)
	800	Space (with individual. water hook-ups)
Campgrounds	225 - 570	Campsite
Mobile Home Park	1,000	Parking space
Motels	150 - 200	Bed space
Hotels	225	Bed space

Source: [https://www.kitchener.ca/en/resourcesGeneral/Documents/INS\\_SSU\\_Design\\_Criteria.pdf](https://www.kitchener.ca/en/resourcesGeneral/Documents/INS_SSU_Design_Criteria.pdf)